

Map ID  
Direction  
Distance  
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number  
EPA ID Number

712  
West  
> 1  
1.009 mi.  
5327 ft.

**POLE TOP 69603**  
**BAYVIEW AVE AND NEPTUNE AVE**  
**BROOKLYN, NY**

**NY Spills S110611493**  
**N/A**

**Relative:**  
**Higher**

**Actual:**  
**9 ft.**

**SPILLS:**

Name: POLE TOP 69603  
Address: BAYVIEW AVE AND NEPTUNE AVE  
City,State,Zip: BROOKLYN, NY  
Spill Number/Closed Date: 1007684 / 2010-11-17  
Facility ID: 1007684  
Facility Type: ER  
DER Facility ID: 396153  
Site ID: 441121  
DEC Region: 2  
Spill Cause: Equipment Failure  
Spill Class: C4  
SWIS: 2401  
Spill Date: 2010-10-20  
Investigator: RWAUSTIN  
Referred To: Not reported  
  
Reported to Dept: 2010-10-20  
CID: Not reported  
Water Affected: Not reported  
Spill Source: Commercial/Industrial  
Spill Notifier: Other  
Cleanup Ceased: Not reported  
Cleanup Meets Std: False  
Last Inspection: Not reported  
Recommended Penalty: False  
UST Trust: False  
Remediation Phase: 0  
Date Entered In Computer: 2010-10-20  
Spill Record Last Update: 2010-11-17  
Spiller Name: Not reported  
Spiller Company: CON ED  
Spiller Address: Not reported  
Spiller Company: 999  
Contact Name: ERT  
DEC Memo: "11/17/10 - Austin - 1/2 gal. transformer fluid leak from pole transformer onto pavement - Con Ed contained and cleaned up spill - See eDocs files for more details -Spill closed - end"  
  
Remarks: "slipp to concrete/clean up pending resources"

**All Materials:**

Site ID: 441121  
Operable Unit ID: 1191697  
Operable Unit: 01  
Material ID: 2186877  
Material Code: 0020A  
Material Name: transformer oil  
Case No.: Not reported  
Material FA: Petroleum  
Quantity: .50  
Units: G  
Recovered: Not reported  
Oxygenate: Not reported